

RESOLUTION 2012-075

RESOLUTION AUTHORIZING THE AWARD OF A CONTRACT
WITH AN ESTIMATED COST BETWEEN \$2,625.00 AND \$17,500.00
WITHOUT PUBLIC ADVERTISING FOR BIDS

WHEREAS, the "Local Public Contracts Law" provides that except for contracts which require the performance of professional services, all contracts or agreements which do not require public advertising for bids and the estimated cost or price is between \$2,625.00 and \$17,500.00, two (2) or more competitive quotations as to cost or price, whenever practicable, shall be solicited by the contracting agent, and the contract or agreement shall be made with and awarded to the lowest responsible bidder; and

WHEREAS, The Bordentown Sewerage Authority has solicited from the following bidders the respective quotations as to the price:

<u>BIDDER</u>	<u>PRICE</u>
Deltronics Corporation	Incomplete
Excelsior Blower Systems Inc	\$6,215.00
Willier Electric Motor Repair Company Inc	\$6,535.00

for the following goods or services:

Hoffman Blower – Disassemble and install new bearings and seals. Install new bearing housing and bearing cap. Assemble and laser align.

WHEREAS, a Certificate of Availability of Funds has been provided by the designated certifying finance officer and is attached hereto.

NOW, THEREFORE, BE IT RESOLVED, this 17th day of September, 2012, that a contract, be and the same is hereby awarded to:

Excelsior Blower System Inc

in the amount of \$6,215.00, for the goods or services described above.

THE BORDENTOWN SEWERAGE AUTHORITY

By: *Ronald L. Marino*
Ronald L. Marino, Chairman

Attest:

Nancy A. Liberman
Nancy A. Liberman, Secretary

I have reviewed this Resolution and the Certificate of Availability of Funds and am satisfied that an appropriate Certificate of Availability has been provided.

Edward A. Kondracki
Edward A. Kondracki, Esquire
General Counsel

CERTIFICATE OF AVAILABILITY OF FUNDS

I, Richard D. Eustace, Executive Director and Certifying Finance Officer of The Bordentown Sewerage Authority, do hereby certify, pursuant to the rules of the Department of Community Affairs, Division of Local Government Services (N.J.A.C. 5:34-5.1 et seq.), that there are available adequate funds for the following proposed contract:

CONTRACT: Hoffman Blower – Disassemble and install new bearings and seals. Install new bearing housing and bearing cap. Assemble and laser align.

CONTRACTOR: Excelsior Blower Systems Inc


CONTRACT AMOUNT: \$6,215.00

BUDGETARY LINE ITEM: 02-004-7610

I certify that the same funds have not been certified as available for more than one pending contract.

9/17/12

Date



Richard D. Eustace
Richard D. Eustace
Certifying Finance Officer

BORDENTOWN SEWERAGE AUTHORITY

QUOTATION RECORD FORM

PROJECT Hoffman Blower Bearing Replacement

DEPT/APPROV. _____

ITEM OR SERVICE: Disassemble and install new bearings & seals.
Install new bearing housing and bearing cap. ~~Assemble~~ Assemble and Laser align.

SOLICITED BY: _____ Phone _____ Letter _____ In Person _____ Newspaper

Quotes not sought _____)
Not awarded to lowest price _____) Statement of explanation
_____) on reverse side

Vendor: Deltronics Corporation Response (time and method) _____

Price Incomplete Delivery _____

Special Terms Did not respond to 2nd and 3rd requests to
update quote.

Vendor: Excelsior Blower Systems, Inc Response (time and method) _____

Price \$6,215 Delivery _____

Special Terms _____

Vendor: Willier Electric Response (time and method) _____

Price \$6,535 Delivery _____

Special Terms _____

Vendor: _____ Response (time and method) _____

Price _____ Delivery _____

Special Terms _____

AWARDED TO: _____ TERMS: _____

COST: _____ SPECIAL COMMENTS: _____

PURCHASE ORDER # _____

SOLICITATION PERFORMED BY OR UNDER SUPERVISION OF:

Thomas Redwood DATE: 9/14/12
(SIGNATURE OF CONTRACTING AGENT)

PRICE QUOTE

Deltronics Corporation
224 Bogden Blvd.
P.O. Box 446
Millville, NJ 08332
Phone (856)825-8200
Fax (856)825-3906

Price Quote # Q-6015

Date: June 20, 2012
Proposed Delivery: 2-3 Weeks
Terms: Net 30 Days
F.O.B.: Job site
Salesperson: 4
Shipped Via: Our truck


Bordentown Sewerage Authority
954 Farnsworth Avenue
Bordentown, NJ 08505
ATTN: Rick/Tom
Fax# 609-291-9079

Re: Sewer Treatment Plant. Hoffman Blower, ser.#67233.

Replace bearings and carbon seal rings in blower, at the jobsite.

FOR THE SUM OF-----\$ 3,011.00

Quote Valid for 30 Days



Submitted by: Ronald D. Richardson



Excelsior Blower Systems, Inc.

Phone: 610.921.9558 • Fax: 610.921.9727
www.excelsiorblower.com

To: Tom Redwood, Bordentown Sewerage Authority
Ph. 609-291-9105
Email: tredwood.bsa@hotmail.com

From: Dennis Larsen

Date: February 28, 2012

Ref: Onsite Bearing Change
Hoffman 2400 Blower/ 60 Hp Motor

Quote No. 71247

Hi Tom,

As per your request, we could do an onsite bearing change on both ends of the Hoffman blower. This service would also include a laser alignment on the unit.

Labor and Parts required for Bearing Change:

Travel and Onsite Labor:	\$1525.00
Bearing Kit 300RGP6023:	2 X \$505—Each
Seal Kit (Two Required):	2 X \$268 -- Each

\$3071.

It is ideal if Bordentown also purchases the bearing carriers and bearing caps for each end, as these can often be found to be out of round or worn when dis-assembling onsite. If the parts are not used, they will be left for spare / future use. Otherwise, if you opt not to pre-purchase these housings/caps, and any are found to be required, a second trip will need to be scheduled once parts arrive.

Recommended Spare Parts:

Bearing Housing 383	2 X \$1,124 x each end
Bearing Cap 383	2 X \$448 x each end

We are quoting only Gardner Denver Lamson OEM factory parts as the Factory Authorized Repair Center for these blowers. Please let me know if you have any questions.

Dennis Larsen

\$ 6215.00

WILLIER

ELECTRIC MOTOR REPAIR CO., INC.

1 Linden Avenue • P.O. Box 98 • Gibbsboro, NJ 08026
(856) 627-3535 • Fax (856) 627-5271

September 11, 2012

Tom Redwood
Bordentown Sewerage Authority
P.O. Box 396 954 Farnsworth Ave.
Bordentown, NJ 08505
609-291-9105

Quotation

Supply Labor and Material to Rebuild Hoffman Centrifugal Blower Serial # 67233, Machine Model 384 On site:

To include:

Disassemble

Replace Bearing Housing Both Ends with New

Replace Bearings with New Bearing Kit

Replace Seals with New Seal Kit

Replace Bearing Cap Both Ends with New

Assemble and Test

Laser Align

Cost to perform this Work...\$6,535.00

Any questions please contact me by Phone 609-922-4460

Thank you,
Kurt M. Schneider