

RESOLUTION 2025-065

**RESOLUTION OF THE BORDENTOWN SEWERAGE AUTHORITY, IN THE COUNTY
OF BURLINGTON, STATE OF NEW JERSEY AUTHORIZING
THE RELEASE OF A PERFORMANCE GUARANTEE
WITHOUT REQUIREMENT FOR MAINTENANCE GUARANTEE**

WHEREAS, The Bordentown Sewerage Authority has caused an inspection to be made of the sanitary sewer main saddle connection for **Block 501 Lot 3.02**, 6 Myrtle Avenue in Bordentown City; and

WHEREAS, the inspection has revealed that the sanitary sewer lateral saddle was installed in accordance with the rules, regulations and specifications of the Authority; and

WHEREAS, the engineers to the Authority have recommended the release of the performance guarantee posted for the lateral saddle improvements; and

WHEREAS, the sanitary sewer lateral extending from the lateral saddle is not the property of the Authority, and will remain the private property of the property owner.

NOW, THEREFORE, BE IT RESOLVED this 19th day of May, 2025, by The Bordentown Sewerage Authority as follows:

1. The sanitary sewer lateral saddle installed for **Block 501, Lot 3.02**, 6 Myrtle Avenue, Bordentown City be and the same are hereby approved by The Bordentown Sewerage Authority.
2. The performance bond # 67126708 previously posted in the amount of \$30,200.00 be and the same is hereby released.
3. The on-site sanitary sewer lateral saddle extension shall not be accepted for ownership or maintenance by The Bordentown Sewerage Authority, but instead, shall continue to be owned and maintained by the property owner.
4. Since the sanitary sewer lateral saddle installed on the Authority's sewer main possessed no obvious deficiencies in the post installation video tape provided by the Applicant and is fully encased in concrete, no maintenance guarantee shall be required.

THE BORDENTOWN SEWERAGE AUTHORITY

By: M. Ellen Gulbinsky
M. Ellen Gulbinsky, Chairwoman

ATTEST:

Joseph R. Malone, III.
Joseph R. Malone, III., Assistant Secretary